

I n t e r n a t i o n a l T e l e c o m m u n i c a t i o n U n i o n

ITU-T

Technical Paper

TELECOMMUNICATION
STANDARDIZATION SECTOR
OF ITU

(13 December 2013)

SERIES L:

CONSTRUCTION, INSTALLATION AND PROTECTION
OF TELECOMMUNICATION CABLES IN PUBLIC
NETWORKS

**Case study of reduction of air-conditioning
energy by optical fibre based thermometry**

ITU-T

Summary

This Technical Paper refers to the Best Practices defined in Recommendation ITU-T L.1300. More precisely, this Technical Paper reports a case study related to the reduction of the energy spent for air-conditioning through the use of optical fibre based thermometry. A general description of the temperature measurement is firstly provided; then the optimization process for the air-conditioning is highlighted. Finally, the results of temperature measurements through optical fibre sensors are shown.

Keywords

Best practice, data centre, energy efficient, information and communication technology and climate change (ICT & CC).

Change Log

This document contains Version 1 of the ITU-T Technical Paper on “*Case study of reduction of air-conditioning energy by optical fibre based thermometry*” approved at the ITU-T Study Group 5 meeting held in Lima, 2-13 December 2013.

Editor: Gianluca Griffa
Telecom Italia
Italy

Tel: +39 331 600 1341

Email: gianluca.griffa@telecomitalia.it

Contents

Page

1	Scope	4
2	Definitions	4
3	Abbreviations.....	4
4	Introduction	4
5	General description of temperature measurement using optical fibre sensors	5
5.1	Principle and system configuration	5
5.2	Features.....	6
6	Optimizing air-conditioning environment of datacentres.....	7
7	Case studies	7
7.1	Basic optical fibre layout.....	7
7.2	A trial at a compact server room	7
7.3	A trial at a large datacentre.....	9
	References and Bibliography	13

List of Tables

Page

Table 1 – Summary of improvements for air-conditioning	9
--	---

List of Figures

Page

Figure 1 – Energy consumption ratio in datacentres.....	5
Figure 2 – Principle of temperature measurement by optical fibre.....	6
Figure 3 – A typical optical fibre layout in a datacentre.....	7
Figure 4 – Server room layout	8
Figure 5 – Changes in temperature distribution depending on air flow direction	9
Figure 6 – A photograph of the target datacentre (Numazu)	10
Figure 7 – Result of rising for temperature setting of air-conditioner	10
Figure 8 – Air flow around servers in a server rack.....	11
Figure 9 – Installed position of floor grills	11
Figure 10 – Improvement of temperature distribution.....	12

ITU-T Technical Paper

Case study of reduction of air-conditioning energy by optical fibre based thermometry

Summary

This Technical Paper describes case study of reduction of air-conditioning energy by optical fibre based thermometry based on Recommendation ITU-T L.1300.

Keywords

Best practice, data centre, energy efficient, information and communication technology and climate change (ICT & CC).

1 Scope

This Technical Paper describes case study of reduction of air-conditioning energy by optical fibre based thermometry based on Recommendation ITU-T L.1300. The scope of this Technical Paper includes:

- a general description of temperature measurement using optical fibre sensors;
- optimizing air-conditioning environment of datacentres; and
- case studies of temperature measurement using optical fibre sensors.

2 Definitions

This Technical Paper uses the following terms:

None.

3 Abbreviations

None.

4 Introduction

Information and communication technology (ICT) systems, which support the ICT society, have been expanding remarkably in recent years due to the spread of the Internet infrastructure and deployment of high-performance servers and other high-end computing systems. This trend has been accompanied by a dramatic increase in the floor space of datacentres and the number of servers that they accommodate, resulting in a significant increase in the power consumption of datacentres.

A datacentre has many servers, generally from a few tens to several thousands, and the working servers generate a considerable amount of waste heat. As a result, air conditioning systems using large-scale air-conditioning equipment have become essential for cooling these servers and keeping the room temperature below the specified value. The power required for air-conditioning, however, has risen to about 40% of the total power consumed by datacentres (Figure 1). Hence, in order to achieve an energy-efficient datacentre, reduction of air-conditioner power consumption is unavoidable.




Figure 1 – Energy consumption ratio in datacentres

Achieving energy-efficient air conditioning requires not only the deployment of high-efficiency air-conditioning equipment, but also optimization of the cooling conditions at the target locations. The temperature settings in server rooms are often rather low to prevent server overheating, despite the fact that excessive cooling results energy loss. There is also concern that cooling efficiency would decrease due to temperature increase of the cooling air that would suck back exhaust heat for various reasons at points (server intake panels) designed to supply chilled air.

Thus, to achieve energy conservation by optimizing the air-conditioning system, an accurate and detailed temperature distribution in the vicinity of servers must be obtained. Temperature measurements have traditionally been performed using discrete temperature sensors like thermocouples, thermistors, and platinum resistance thermometer bulbs, and integrated-circuit-type temperature sensors. However, taking into consideration the temperature measurement of a few hundred to several thousand servers, it is impractical to utilize discrete sensors due to several limitations which include high construction cost, difficulty in installation of signal-circuits, difficulty in shortening of measurement time, and so on. Accordingly, to achieve a temperature measurement technique that can handle such a large array of servers, an optical-fibre-based temperature measurement technique has been developed, and tested to prove its usability to reduce the energy consumption in datacentres.

5 General description of temperature measurement using optical fibre sensors

5.1 Principle and system configuration

Raman-scattering light measurement is widely used in optical-fibre-based thermometric sensing methods. Raman-scattering light is generated in a transparent substance when irradiated with a strong LASER stimulating light. Raman scattering consists of two types of light rays called anti-Stokes light and Stokes light. Anti-Stokes light has a 50 nm shorter wavelength than the injected light, and it is sensitive to the temperature changes in the optical fibre. Stokes light has a 50 nm longer wavelength than the injected light and it is not so sensitive to temperature changes. By measuring the intensity ratio of these two types of light, we can determine the temperature distribution along the entire length of an optical fibre

In more detail, a LASER light in the form of short pulses with several nanosecond pulse width is injected into an optical fibre. Then, while the light propagates through the optical fibre, the backscattering intensity of Raman-scattering light generated at various locations in the optical fibre

is measured together with the delayed propagation time. The principle behind this technology is shown in Figure 2. The change in intensity versus propagation time is plotted (Figure 2, upper right). Signal conversions from light intensity to temperature and propagation time to fibre distance (Figure 2, lower right) gives the temperature distribution along the fibre. The distances of locations are computed by multiplying the delayed propagation time of the Raman scattering light by the speed of the light propagation in the optical fibre (about 2×10^8 m/s). In a 10-km-long optical fibre, for example, excitation light takes about $50\mu\text{s}$ to arrive at the other end, which means that temperature information along the entire 10 km of the optical fibre can be obtained within about $100\mu\text{s}$.




Figure 2 – Principle of temperature measurement by optical fibre

The temperature distribution measurement in optical fibres using Raman scattering light is considered to be very promising in real time multipoint thermometry.

5.2 Features

Optical-fibre-based thermometry has some excellent features described below;

- Real-time multi-point measurement

Since the temperature measurement is carried out based on an optical process, up to 10,000 temperature data points along the fibre laid on target areas can be obtained within every 30 sec intervals.

- High resolution & high accuracy

Maximum resolution is 10 cm, and accuracy is $\pm 1^\circ\text{C}$.

- Capability to visualize temperature distribution

By utilizing high resolution thermometry given above, the temperature distribution in a datacentre can be obtained as thermographic image data. A user can easily understand the thermal environment of the datacentre, and this would help to improve the air-conditioning efficiency.

6 Optimizing air-conditioning environment of datacentres

According to the temperature distribution, the air-conditioning environment can be improved to a more energy efficient one by optimising several air-conditioning parameters. For example, air flow direction, flow rate, and temperature control settings are the most effective parameters for improving the energy efficiency.

7 Case studies

7.1 Basic optical fibre layout

Representative optical fibre layout is shown in Figure 3. Rack installation pattern is almost rectangular along each front side and back side door frames. Optical fibre laid on the front side door is more important to monitor the temperature of the inlet cooling air to each server. Optical fibres on each door were connected together at the base of each server rack to make a single optical fibre circuit. Fibre laying on the ceiling was done in a parallel pattern with a spacing of 30 - 50 cm and 10 - 30 cm above from the top of server racks.




Figure 3 – A typical optical fibre layout in a datacentre

7.2 A trial at a compact server room

A trial on site temperature measurements and improvement of air-conditioning environment was conducted at a small server room; Fujitsu Kyushu Office. The server room was equipped with 14 server racks and 2 indoor air-conditioner units (Figure 4).

First, a conventional air-conditioning system was studied (Figure 4-(A)). From the data, it was found that the cold air blew out from the air-conditioner was almost straight and parallel to the longitudinal direction of the server room. In this condition, supplied cold air got mixed with the hot exhaust from the servers, and the cooling efficiency of the servers was found to be rather low. Then, tuning of the wind direction and temperature setting were done while monitoring the temperature distribution by the optical fibre thermometry system.

Case 1: By changing the cold air direction as shown in Figure 5-(B), cooling efficiency was improved; this made it possible to increase the air-conditioner temperature. In this case, power consumption of air-conditioning system was reduced by 11%.

Case 2: Without changing the cold air flow direction of Case 1, one air-conditioner was stopped (Figure 5-(C)). Here, we found that it is possible to supply cold air below 28°C to all servers. From these two changes, it was possible to reduce the power consumption by 36% compared with the conventional conditions.

Case 3: Another air-conditioner was stopped while keeping all the other conditions of the case 2 unchanged (Figure 5-(D)). In this case, air-conditioning power consumption reduction was reached to 23%. Results of the above improvements are summarized in Table 1.

Tuning of wind direction can be completed within 30 minutes for all cases. After tuning, it took 1 to 2 hours for measuring and verifying power consumption of the air conditioner.




Figure 4 – Server room layout




Figure 5 – Changes in temperature distribution depending on air flow direction

Table 1 – Summary of improvements for air-conditioning

Cooling Condition		Set Temp. of AC#1	Set Temp. of AC#2	Air Flow Direction	Total Power Consumption of ACs(kW)		Reduction Rate
					Indoor Unit	Outdoor Unit	
Conventional		22°C	23°C	Mixed with hot exhaust	5.6		–
					2.3	3.3	
Case1	Change of air flow direction	24°C	24°C	Supplied to cold aisle	5.0		11%
					2.3	2.7	
Case2	Stop AC#2	24°C	Shutdown	Supplied to cold aisle	3.6		36%
					1.2	2.4	
Case3	Stop AC#1	Shutdown	24°C	Supplied to cold aisle	4.3		23%
					1.2	3.1	

7.3 A trial at a large datacentre

Another trial was done in a large datacentre; Fujitsu Numazu Cloud Centre.

Optical fibre sensors were laid on more than 30 racks and more than 170 m² ceiling area (Figure 68).



Figure 6 – A photograph of the target datacentre (Numazu)

In this datacentre, the initial set temperature of the air-conditioner was 19°C, and it was found that there were several overcooled server racks (Figure 7, left). The set temperature was gradually raised, and temperature distribution of all of the server racks and ceiling area was continuously measured to check whether abnormal temperature rise has occurred. When the set temperature reached to 2°C above the original value (19°C), some overheated spots appeared on the front side door of server racks (Figure 7, right). To prevent function failure, this approach was interrupt immediately, and the cause of this problem was investigated.




Figure 7 – Result of rising for temperature setting of air-conditioner

By detailed examination around the server racks, 2 types of problems were identified.

- (1) Hot exhaust backflow

We found that there were some vacant spaces in some server racks near to the hot spots. It is believed that hot exhaust returned to the front side through these vacant spaces (Figure 8, left).

(2) Insufficient cooling air flow

Cooling air was supplied through several floor grills to the each server rack. We noticed that the floor grills had been placed unevenly. This led to insufficient cooling of the servers adjacent to the troubled server racks (Figure 9, left).




Figure 8 – Air flow around servers in a server rack




Figure 9 – Installed position of floor grills

Improvement of air flow was carried out as follows:

- Blank panels were installed to the vacant spaces in the server racks.
- The number of floor grills was increased, and installing positions were adjusted while checking the temperature distribution continuously.

As a result, highly uniformed temperature distribution on each server rack was achieved, and the set temperature was able to increase further. As the final result, the datacentre set temperature was able to increase by 5.5°C (Figure 10). Although this study was conducted in only a part of the

datacentre, the power consumption reduction of air-conditioning system of the entire datacentre was estimated to be about 6%.




Figure 10 – Improvement of temperature distribution

References and Bibliography

[ITU-T L.1300]

Recommendation ITU-T L.1300 (2011), *Best practices for green data centres*.
