

Lessons and Learned

Communication Problems of the Fukushima Nuclear Power Plant No.1 Accident



Isao Nakajima, M.D., Ph.D., Ph.D.

**Researcher, the National Diet of Japan Fukushima Nuclear
Accident Independent Investigation**

Co-Rapporteur for eHealt, ITU-D SG2 Q2/2

Professor, EMS Tokai University School of Medicine, Japan

Agenda



1. **Who we are.**
2. **What happened, Fukushima Nuclear Power Plant Unit #1 ,#2, #3**
3. **Trouble and damage of the communication system in Fukushima**
4. **Conclusions**



10 Years History of ITU e-Health Expert Training Courses Tokai University, Japan.

Document RGQ14-3/2/INF/22-E





**Tokai University Shonan Campus
Hiratsuka Kanagawa Japan**



**Tokai University Hospital
Isehara Kanagawa Japan**

<http://www.tsj.gr.jp/tsj/tumri/nakajima/index.htm>


Novel Mobile Telemedicine System for Real-time Transmission of 12-lead ECG Data and Live Video from Moving Ambulance to Hospital



What does NBC mean?

Nuclear disaster

NBC stands for Nuclear, Biological, Chemical. It is a term used in the armed forces and in health and safety, mostly in the context of weapons of mass destruction (WMD)



NBC 対処訓練を行う陸自第2化学防護隊（北海道）

ITU-MIC Regional Meeting on ICT for e-Health


Tokyo Japan, 10-11 March 2011




Rapporteur and Vice Rapporteurs for Q14

The Great East-Japan Earthquake

stroke on March 11, 2011



Boiling Water Reactor System



Fukushima Daiichi NPP




Fukushima Dai-ichi NPP

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
	BWR-3	BWR-4	BWR-4	BWR-4	BWR-4	BWR-5
PCV Model	Mark-1	Mark-1	Mark-1	Mark-1	Mark-1	Mark-2
Electric Output (MWe)	460	784	784	784	784	1100
Max. pressure of RPV	8.24MPa	8.24MPa	8.24MPa	8.24MPa	8.62MPa	8.62MPa
Max. Temp of the RPV	300• •	300• •	300• •	300• •	302• •	302• •
Max. Pressure of the CV	0.43MPa	0.38MPa	0.38MPa	0.38MPa	0.38MPa	0.28MPa
Max. Temp of the CV	140• •	140• •	140• •	140• •	138• •	171• (D/W) 105• (S/C)
Commercial Operation	1971,3	1974,7	1976,3	1978,10	1978,4	1979,10
Emergency DG	2	2	2	2	2	3*
Electric Grid	275kV × 4				500kV × 2	
Plant Status on Mar. 11	In Operation	In Operation	In Operation	Refueling Outage	Refueling Outage	Refueling Outage

* One Emergency DG is Air-Cooled


Source: Application document of license for establishment of NPP

Before construction, it was the hill of the altitude of 35m. As the ability of the seawater suction pump of GE was low, so sharpened it to an **altitude of 10m expressly and built a power station**



The height of the breakwater was 5.7m.

**Tokyo Electric employee reports to an academic society
before the Fukushima nuclear power plant accident**
the Probability of Expectance during 50 Years
Tsunami over the water wall of 5.7m by 4% !!!



Episode after the major earthquake

March 11, 14:46

Earthquake 9.0 magnitude strikes East Japan



Reactors(#1-#3): Automatic shut down



Power plant to be cut off from the Japanese electricity grid



Back-up diesel generators start



March 11, 15:01

14 meters high tsunami wave strikes Fukushima Dai-chi



March 11, 15:42

**All AC power sources for Units 1 through 3 at Fukushima I were lost
(Back-up diesel generators fail) / Report to “the Law” (Loss of power)**



March 11, 16:36

Water injection failed to function in the Emergency Core Cooling System



March 12, 00:49

Abnormal rise of CV pressure

DC 115V power supply battery



Opened AO valve by a nitrogen gas cylinder for the vent decompression



Confirmation of a blowout panel



April_25_2019 Odessa




Japanese government report to IAEA Fukushima “worse than meltdown?”

Deterioration in nuclear reactors' condition


(hours after Great East Japan Earthquake)

	STATE OF NUCLEAR REACTORS	ANALYSIS BY NISA	ANALYSIS BY TEPCO
No. 1 reactor	start of damage to reactor core	3 hours later	4 hours later
	breach of pressure vessel	5 hours later (8 p.m. on March 11)	15 hours later
No. 2 reactor	start of damage to reactor core	77 hours later	77 hours later
	breach of pressure vessel	80 hours later (10:50 p.m. on March 14)	109 hours later
No. 3 reactor	start of damage to reactor core	44 hours later	42 hours later
	breach of pressure vessel	79 hours later (10:10 p.m. on March 14)	66 hours later

By the operators mistake, IC was switched off. As a result, within early stage of 24 hours, **MarkI caused core fusion.**



Unit : mSv/h



April 25 2019 Odessa


Because a blowout panel dropped naturally, the II unit #2 didn't explode

The hydrogen vent gas flowed backward from an opened valve into the I unit building and exploded several hours later.



Trend of the radiation exposure dose

Fukushima Nuclear Accident - Radiation Comparison



from the web

<http://japan.resiliencesystem.org/fukushima-nuclear-incident-radiation-comparison>

April_25_2019 Odessa

- ## Comparison from Chernobyl


I131 **9%**

(courtesy Prof. Tilman Ruff, Nossal Institute for Global Health)



Marine Pollution

Radioactive Seawater Impact Map (update: 10.08.11)



The contaminated water is not controlled at all.



Summary of Accidents


Falling water levels uncover cores 1, 2, and 3

- Cores mostly uncovered for 8 to 20 hours
- Fuel temperature rises to 1200oC and as much as 2500oC
- Zirconium cladding burns: $\text{Zr} + 2\text{H}_2\text{O} = \text{ZrO}_2 + 2\text{H}_2$
- Hydrogen and noble gases vented as vessel pressure rises
 - But the vent's exhaust is inside the building's service level
- Random spark ignites the hydrogen; blows off frangible panels
 - Looks much worse than it really is

Spent fuel cooling pools also begin to dry up


- Spent fuel still warm ? and hastens water's evaporation
- Goes unnoticed because monitors are dead and no one up there

Relationship between Cut-off Electric Power and Loss-function Stations of NTT DoCoMo



Great East-Japan Earthquake Service Area Restoration Status

As of March 12



Service out at 4,900 base stations
Tohoku (north-east Japan)

Major causes of interruption

Direct damage from
earthquake/tsunami
(damage, submersion, etc.)


Transmission line disruption due to
earthquake (optical fiber, etc.)

Batteries depletion due to
long-term power outage

Service disrupted

Service available

As of April 26



Restored service areas to nearly pre-disaster levels
Tohoku (north-east Japan)

NTT DoCoMo's website


http://www.nttdocomo.co.jp/english/binary/pdf/corporate/technology/rd/technical_journal/bn/vol13_4/vol13_4_096en.pdf


April_25_2019 Odessa

25

Recovered base stations of NTT DoCoMo after the disaster

< Fukushima, Miyagi, Iwate >





Disaster Prevention, Caution Communication System in Japan

**1. Cities, towns and villages disaster prevention
administration radio**


**2. LASCOM :Local Authorities Satellite Communications
Organization**

3. Nuclear Power Plant Satellite Networks

Inmarsat after March, 2010, such as JAEA, Ministry of Education,
Culture, Sports, Science and Technology, a nuclear power plants

**4. J-ALERT National second warning system
transmits emergency information to the people in case of
critical situation**

Number of concurrent use of communication channels




This graph represents how much communication has been made at the same time.



The Act on Special Measures Concerning Nuclear Emergency Preparedness (“Nuclear Emergency Preparedness Act”) and the Nuclear Emergency Response Manual of the Government stipulate that once a nuclear accident occurs, a local nuclear emergency response headquarters (“local NERHQ”) shall be established close to the accident site, as the center of the emergency response coordination. A local NERHQ is to be located at a local standing facility for emergency responses and measures (“Off-site Center”).

Trouble of the circuit of the SPEEDI

SPEEDI :Prediction of Environmental Emergency Dose Information



The Network System for Prediction of Environmental Emergency Dose Information (SPEEDI) is expected to play an important role in protecting local population from radiation exposure and the planning of evacuation.


However, the system was not utilized when evacuation was instructed.

The communication links were **disrupted for 2 months** and inoperative due to the earthquakes, and the SPEEDI could not receive the basic source term information of released radioactivity.

It was therefore not possible for the SPEEDI to estimate atmospheric dispersion of radioactive materials on the basis of the basic source term information.

Trouble of the circuit of the SPEEDI


SPEEDI :Prediction of Environmental Emergency Dose Information




ITU Inmarsat mobile phone

153 terminals for free

Why? Not distributed in Fukushima




Delay of an evacuation directive and the evacuation order



Information was delay in the outside of the concern area where a nuclear power plant was located. These inhabitants failed to get out in time and received useless radiation exposure.



Radiation releases, 11-20 March 2011



(courtesy Prof. Tilman Ruff, Nossal Institute for Global Health)

April_25_2019 Odessa

Dictation Notice of Weather Map by NHK AM Radio on March 15, 2011



Stable Iodine after Fukushima



1. Regrettably, the Government did not give prompt orders for administering stable iodine after the nuclear accident. Even though some municipal authorities had stocks of stable iodine, they were not distributed. Some municipalities, such as Futaba and Tomioka, distributed stable iodine without orders from the Government.
2. The decision to administer stable iodine had been delayed because of apprehension of potential harmful side effects that iodine prophylaxis could cause. However, it is an accepted position in radiological medicine that even where the absorbed dose is less than 100mGy, stable iodine should be administered, as it does not entail any significant health hazards.

Conclusions

Disaster Communications and Medicine

- The gateway stations for Mobile phone were unable to function.
- Even the mayor of the district concerned knew the evacuation advisory to hear via only **police radio** for the first time.
- Many residents of Fukushima were intellect and ignorant of the order of " the Final Decision :evading“ Therefore **the exposure doses of many inhabitants increased.**
- **Communication was insufficient, and stable iodines were not able to be given to inhabitants.**



Nakajima's Personal Impression

1. The risk of nuclear power plant accident is similar to a Formula 1(racing car) running at full speed on a public road without brakes. It has to crash.
2. Whatever politicians or the Government said, they were only lies.
3. They learned absolutely nothing even after the nuclear disaster.
4. Nuclear sector can't go on just doing business as usual, may be all over the world.